



State of North Carolina
Department of Environment, Health and Natural Resources
Winston-Salem Regional Office

James G. Martin, Governor
William W. Cobey, Jr., Secretary

Division of Environmental Management
Groundwater Section

Margaret Plemmons Foster
Regional Manager

August 7, 1992

Kyle's Friendly Service
127 Blue Bell Road
Greensboro, NC 27406

Subject: Underground Storage Tank Closure,
New Home Building Supply #2, 625 S. Mendenhall St.
Greensboro, North Carolina 27406

Gentlemen:

On May 30, 1990, we received the soil sample results and closure assessment from the underground storage tank closure at the subject location. As the implementing agency for the Federal Underground Storage Tank Program for the State of North Carolina, we have determined from review of your assessment that the UST system has been closed in accordance with NCAC Title 15A Subchapter 2N Section .0802 and .0803 and 40 CFR 280.71 and 280.72. However, this does not absolve you of any responsibility for contamination that may not have been detected or noted during the site assessment.

If you have any questions, please feel free to contact Thomas Salley or me at the letterhead address or telephone number during the hours of 9:00 a.m. to 10:00 a.m. and 1:30 to 2:30 p.m.

Sincerely,

A handwritten signature in cursive script, appearing to read "W. Waddell Watters".

W. Waddell Watters
Hydrogeologist II

WWW/dh

cc: ~~NR~~ ~~NR~~

Central Files - Guilford County

UNDERGROUND STORAGE TANKS (UST's)

New Home Building Supply

(CHECK APPROPRIATE RESPONSE)

REGULATED



NONREGULATED

RELEASE CONFIRMED ?

YES

NO

CLEAN-UP INITIATED ?

YES

NO

TANKS REMOVED ?

YES

NO

RELEASE UNDER CONTROL ?

YES

NO

CLEAN-UP COMPLETED ?

YES

NO

Clear Closure as 1989 Requirements